


REVISION HISTORY		
REV	DATE	ECN
–	09/24/08	08–0476
A	03/04/09	09–0302
B	04/28/09	09–0573
C	02/24/10	10–0227
D	04/06/10	10–0465
E	08/23/10	10–1256

NOTES:

- A. UNITS ARE FABRICATED OF GALVANIZED STEEL
- B. WITH A 16 GA GALVANIZED FAN DECK
- C. THERMOSTATS SHIPPED LOOSE FOR FIELD INSTALLATION.
- D. BLOWER, MOTOR, VALVES, COIL, AND FILTER ARE ACCESSIBLE THROUGH THE RETURN AIR OPENING.
- E. UNIT AND CONTROL BOX ARE INSULATED WITH 1/2" (13) COATED GLASS FIBER INSULATION.
- F. ALL RISERS WILL SHIP SEPARATELY FROM UNITS
- G. DRAIN KNOCK-OUTS ON THREE SIDES OF CABINET
- H. HOSES SHIP W/UNIT BUT ARE NOT SHOWN.
- I. THREADED FITTINGS MUST BE FIELD TIGHTENED AND LEAK TESTED
- J. DIMENSIONS ARE IN INCHES, DIMS IN ( ) ARE IN MM.
- K. RETURN AIR PANEL NOT SHOWN.

MODEL	SIDE SUPPLY			TOP SUPPLY			DIMENSIONS				FILTER SIZE
	A	B	SIZE	C	D	SIZE	E	F	H	I	
MUY03	14 (356)	12 (305)	14X12	14 (356)	10 (254)	14X10	17 (432)	3 (76)	1-1/2 (38)	14 (356)	12-1/2 X 24-1/4 X 1 (318X616X25)
MUY04	18 (457)	12 (305)	18X12	16 (406)	12 (305)	16X12	20 (508)	1 (25)	2 (51)	18 (457)	16-1/4 X 26-3/4 X 1 (413X679X25)
MUY06	22 (559)	16 (406)	22X16	18 (457)	16 (406)	18X16	24 (610)	1 (25)	3 (76)	22 (559)	20-1/2 X 29-1/4 X 1 (521X743X25)

TITLE MUY UNIT			
MODEL MUY			
JOB NUMBER			
JOB NAME			
DRAWN BY D. MCGOUGH			
DRAWING NUMBER I100-90008402	REVISION E	SHEET 1 OF 1	